

Annual Campus Fire Drills 2012

Semester	Year	Type of Action	Date	Time of Day	Area	Building(s)	Rally Location	Evacuation Time (min:sec)	Report Filed by Staff	Follow up needed?	Response of Building Occupants	Notes	Follow up Notes
Spring	2012	Fire Drill	1/24/2012	9:00 AM	COPS	85	Each end of bldg. - grassy area away from parking lots and hydrants	2:00	Yes	No	Excellent		
Spring	2012	Fire Drill	1/24/2012	9:15 AM	COPS	86	grassy area away from parking lots and hydrants	1:45	Yes	No	Excellent		
Spring	2012	Fire Drill	1/24/2012	9:30 AM	Field House	54	Grassy area in front of bldg. toward tennis courts	3:00	Yes	No	Good	Students near weight room did not evacuate until told to do so!	
Spring	2012	Fire Drill	1/24/2012	10:30 AM	HLS	72		2:30	Yes	No	Excellent	Excellent evacuation - Bldg cleared in less than five min. Note: some students/staff crossed four lane street toward water tower - created traffic issues as they	
Spring	2012	Fire Drill	1/24/2012	10:40 AM	Pool	73	Grassy area in front of bldg. toward tennis courts	:45	Yes	No	Excellent		
Spring	2012	Fire Drill	1/24/2012	10:50 AM	COPS	70	Grassy area in front and to right of bldg.	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	1/31/2012	9:00 AM	Pres. Bldg.	10	Flag pole entrance to B12	1:45	Yes	No	Excellent		
Spring	2012	Fire Drill	1/31/2012	9:10 AM	CAS Dean	11	Grassy area near B12	2:00	Yes	No	Excellent	3 alarms (noise makers)	
Spring	2012	Fire Drill	1/31/2012	9:20 AM	Registration	18	Grassy areas on either side of bldg.	3:00	Yes	No	Good	Three staff members slow evacuating	
Spring	2012	Fire Drill	1/31/2012	9:40 AM		36	Grassy areas on either side of bldg.	2:00	Yes	No	Excellent	Hearing impaired staff out early; Math lab - student told to get out	
Spring	2012	Fire Drill	1/31/2012	9:50 AM	Nursing	37	Grassy area rear of bldg.	1:30	Yes	No	Excellent	Alarm not working - schedule re-pull 2/10/12	
Spring	2012	Fire Drill	1/31/2012	10:00 AM	SBA	38	Grassy area near B38	3:00	Yes	No	Good	Three staff members slow evacuating; Staff member w/physical disab. out b-4 others	
Spring	2012	Fire Drill	2/2/2012	8:00 AM	Biology/Chemistry	58	Grassy area between sidewalk and parking lot - behind B6 (trailer)	2:00	Yes	No	Excellent	Upstairs auto fire doors did not close	Joe Stephenson observed problem with fire door.

Annual Campus Fire Drills 2012

Spring	2012	Fire Drill	2/2/2012	8:25 AM	Commons	22		3:00	Yes	Yes	Good	Post Office fire door did not close properly; Three Argo Gally staff slow to evacuate (making sandwich); Chartwell's staff member upstairs moving cart - did not attempt to evacuate until told to do so!	Joe Stephenson observed.
Spring	2012	Fire Drill	2/2/2012	9:40 AM	Psychology	41	Grassy area in Camillia garden	1:00	Yes	No	Excellent	Staff very prepared and helpful w/evacuation	
Spring	2012	Fire Drill	2/2/2012	10:00 AM	Wetland's Lab (CEDB)	83	Grassy/treed area recently cleared	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	2/7/2012	8:05 AM	Science Lab & Lecture	58A	Grassy/treed area recently cleared behind B83	1:30	Yes	No	Excellent		
Spring	2012	Fire Drill	2/7/2012	8:20 AM		50	Grassy area to front & rear of Bldg.	1:30	Yes	Yes	Excellent	No audible in upstairs hallways - close door can barely hear alarm	
Spring	2012	Fire Drill	2/7/2012	8:20 AM		51	Grassy area to front & rear of Bldg.	1:30	Yes	No	Excellent		
Spring	2012	Fire Drill	2/7/2012	8:30 AM		52	Grassy area to front & rear of Bldg.	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	2/7/2012	8:50 AM	Business Classrooms	74	Grassy area to front & rear of Bldg.	2:20	Yes	Yes	Good	Problem: Two large classrooms slow to evacuate (Williams Mgmt. class ACG-2021? & Randolph Acct. class); Kimball MAR-4412 class - good instruction to students (some evac. thru window)	
Spring	2012	Fire Drill	2/7/2012	9:10 AM	Business Offices	75	Grassy area to front & rear of Bldg.	1:00	Yes	No	Excellent	No alarm in bldg. - responded to B76 alarm	
Spring	2012	Fire Drill	2/7/2012	9:10 AM	Business Dept.	76	Grassy area to front & rear of Bldg.	1:30	Yes	No	Excellent		
Spring	2012	Fire Drill	2/9/2012	8:17 AM	Health Center	960	B77 Hallway	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	2/9/2012	8:40 AM	Computer Science	79	Each end of bldg. - Sidewalk along parking lot ?	1:30	Yes	No	Excellent		
Spring	2012	Fire Drill	2/9/2012	9:00 AM	Science & Engineering	4	Grassy area facing B82 - direction and assembly area signs	3:00	Yes	Yes	Good	Staff very prepared and helpful w/evacuation; 2nd floor fire door stuck (not closing properly)	
Spring	2012	Fire Drill	2/9/2012	9:30 AM	COPS	77	Grassy area facing between B77 and B960	3:00	Yes	Yes	Good	Alarms not sounding in hallway (mid level)	
Spring	2012	Fire Drill	2/9/2012	9:30 AM	COPS	78	Parking lot ?	3:00	Yes	No	Good		

Annual Campus Fire Drills 2012

Spring	2012	Fire Drill	2/9/2012	9:45 AM	International House	71	Grassy/treed area facing B82	1:45	Yes	No	Excellent	Disabled person evacuated w/no problem; Person in office shutting down computer - last person out!	
Spring	2012	Fire Drill	2/9/2012	9:00 AM	Facilities Mgmt.	91	Parking lot/garden area	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	2/9/2012	9:10 AM	Building Services Mgmt.	92	Parking lot/garden area	1:00	Yes	No	Excellent		
Spring	2012	Fire Drill	2/9/2012	9:20 AM	Nursing	37	Grassy area rear of bldg.	1:00	Yes	Yes	Excellent	Pull station blocked at front entrance	
Spring	2012	Fire Drill	2/9/2012	9:30 AM	Arch/Enviro.	13	Service Road behind bldg.	2:00	Yes	No	Excellent	Cassidy Hobbs sat at desk until asked to leave; Another prof. refilling coffee after alarm sounded	
Spring	2012	Fire Drill	2/9/2012	9:45 AM	HR	20E	Grassy area between 20E and B22	1:00	Yes	No	Excellent	Staff very prepared and helpful w/evacuation	
Spring	2012	Fire Drill	2/9/2012	9:45 AM	Finance	20W	Grassy area between 20W and B22	1:00	Yes	No	Excellent	Staff very prepared and helpful w/evacuation	
Spring	2012	Fire Drill	2/23/2012	9:00 AM	Art Bldg.	82	Grassy area in front of bldg. - Near water fountain	2:30	Yes	Yes	Excellent	Close studio doors during evac.; Costume shop could not hear alarm; Approx. 3 ft. boiard placed in rope to prevent fire curtain from dropping; Boxes and other items on stage block fire curtain from extending to the floor; Numerous extension cords through out theatre area.	Discussed issues in theatre dept. with Jerri Brisky; Work order submitted 2/29/12 - increase volume of alarm system and have all systems checked in the building.